

DIVISION 1
DISTRICT 11

BOSTON FIRE DEPARTMENT FIRE PREVENTION DIVISION

1010 MASS AVE., 4TH FLR BOSTON MA 02118
Legal Unit 617-343-2182 FAX 617-343-3696

V13816-A
VIOLATION #

NOTICE OF VIOLATION

Date: Oct 31, 2019

Responsible Party Michelle Lawton Owner
FIRST, LAST NAME (INDICATE OWNER/OCCUPANT OR LIST CONDO TRUST/ASSOCIATION IF APPLICABLE)

Mailing Address 541 Menauhant Road East Falmouth, Ma. 02536
(CITY, STATE, ZIP - PO BOX IS NOT ACCEPTABLE)

Inspection of the premises located at: Roast Beast 1082 Commonwealth Ave. Allston, Ma. 02215
VIOLATION ADDRESS (CITY, STATE, ZIP)

reveals violation(s) of fire laws herein specified below:

Boston Fire Prevention Code: _____

M.G.L., Chapter 148 Section: _____

Comm. of Mass. Regs: 527 CMR 1.00 Chapter: 50.1.1

You are hereby ordered to correct the condition(s) enumerated below as directed FORTHWITH WITHIN 15 DAYS

You must submit within 30 Days to the BFD Fire Prevention Fire Marshals Office a signed contract to install a commercial kitchen exhaust system with fire suppression that meets all applicable NFPA-96 Standards for the 2 commercial cooking flat top griddles being used, or submit documentation that replacement cooking equipment meets ANSI-UL 197 Standards for reduced emissions.

**FAILURE TO COMPLY WILL
RESULT IN COURT ACTION**

THIS NOTICE SERVED: IN HAND VIA MAIL

Michelle Lawton Owner
Print Name, Title
541 Menauhant Road
Mailing Address (PO Box is not accepted)
East Falmouth, Ma. 02536
City, State and Zip

Per Order: 
FIRE COMMISSIONER/CHIEF OF DEPARTMENT

Boston Fire Department Official use only:

SERVED BY: Inspector David Hayes
Print Title and Name

Fire Prevention Special Occupancy
Company Group No.

Signature _____ Date _____

 Oct 31, 2019
Member Signature Date